



- NOTES
1. INSTALL IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS.
 2. PROVIDE CONNECTION TO ELECTRICAL SERVICE PER NEC AND CHICAGO CODE.
 3. PROVIDE CONNECTION OF GAS SERVICE IN ACCORDANCE WITH ANSI/AGA Z223.1.
 4. PIPE RELIEF VALVES TO 6' ABOVE FLOOR WITH PROPER SUPPORT AND DRAIN CONNECTIONS TO NEAREST FLOOR DRAIN WHERE PRACTICAL.
 5. INSULATE ALL STEAM AND CONDENSATE PIPING AND ALL FUE PIPE IF SINGLE WALL PIPE.
 6. PROVIDE MANUFACTURER'S START-UP SERVICES.
 7. TUBE REMOVAL CAN BE ACCOMPLISHED FROM THE FRONT OR REAR OF THE BOILER.

	SQUARE HEAD DIX CONTROL VALVE
	GATE VALVE
	GAS VALVE
	CHECK VALVE W/PT DR FLNG
	STRAINER W/PT DR FLNG
	T & P RELIEF VALVE
	DRAIN
	OVERFLOW TRAP

REV	DATE	DESCRIPTION	BY	CHKD
1	01/24/01	REVISION		
2	01/24/01	DATE		

MELLNER

 TUBESHAPE: 30" DIA.

 PART NUMBER: 2B2P2V MD

 SIZE:

 REV:

SAMPLE PIPING DIAGRAM ONLY